



# CHAPLEAU DRINKING WATER SYSTEM

## 2021 ANNUAL COMPLIANCE AND SUMMARY REPORT



Prepared by the Ontario Clean Water Agency  
on behalf of the Township of Chapleau

## TABLE OF CONTENTS

Introduction .....	1
SECTION 11 ANNUAL REPORT.....	2
System Information .....	2
Report Availability.....	2
Description of the Drinking Water System .....	2
Water Treatment Chemicals Used.....	3
Significant Expenses Incurred to the Drinking Water System .....	3
Reported Adverse Test Results and Other Problems .....	4
Schedule 7 – Operational Testing.....	4
Schedule 10 – Microbiological Testing .....	4
Schedule 13 - Nitrate and Nitrite at the Water Treatment Plant.....	5
Schedule 13 – Total Trihalomethanes in the Distribution System .....	5
Schedule 13 – Haloacetic Acids (HAA) in the Distribution System .....	5
Schedule 13 – Sodium at the Water Treatment Plant.....	5
Schedule 13 – Fluoride at the Water Treatment Plant.....	6
Schedule 15.1 – Lead in the Distribution.....	6
Schedule 23 – Inorganic Parameters at the Water Treatment Plant .....	6
Schedule 24 – Organic Parameters at the Water Treatment Plant.....	7
Additional Testing and Sampling .....	8
Schedule 22 – Summary Reports for Municipalities.....	9
Permits and Licences .....	9
Requirements the System Failed to Meet .....	9
Summary of Quantities and Flow Rates.....	10
Monthly Summary of Water Takings from the Kebsquasheshing River.....	10
Monthly Summary of Treated Water Supplied to the Distribution System .....	11
Flow Monitoring.....	11
Summary of Flow Comparison.....	11
Comparison of Raw Flows to System’s Permit to Take Water .....	11
Comparison of Treated Flows to System’s Municipal Drinking Water Licence .....	12

## INTRODUCTION

Municipalities throughout Ontario are required to comply with Ontario Regulation 170/03 made under the *Safe Drinking Water Act*, 2002. The Act was passed following recommendations made by Commissioner O'Conner after the Walkerton Inquiry. The Act's purpose is to protect human health through the control and regulation of drinking-water systems. O. Reg. 170/03 regulates drinking water testing, use of licensed laboratories, treatment requirements and reporting requirements.

O. Reg. 170/03 requires the owner to produce an Annual Report, under Section 11. This report must include the following:

1. Description of system and chemical(s) used
2. Summary of any adverse water quality reports and corrective actions
3. Summary of all required testing
4. Description of any major expenses incurred to install, repair or replace equipment

This Annual Report must be completed by February 28 of each year.

The regulation also requires a Summary Report which must be presented and accepted by Council by March 31 of each year for the preceding calendar year reporting period.

The report must list the requirements of the Act, its regulations, the system's Drinking Water Works Permit (DWWP), Municipal Drinking Water Licence (MDWL), Certificate of Approval (if applicable), and any Provincial Officer Order the system failed to meet during the reporting period. The report must also specify the duration of the failure, and for each failure referred to, describe the measures that were taken to correct the failure.

The *Safe Drinking Water Act*, 2002 and the drinking water regulations can be viewed at the following website: <http://www.e-laws.gov.on.ca>.

To enable the Owner to assess the rated capacity of their system to meet existing and future planned water uses, the following information is also required in the report.

1. A summary of the quantities and flow rates of water supplied during the reporting period, including the monthly average and the maximum daily flows.
2. A comparison of the summary to the rated capacity and flow rates approved in the systems approval, drinking water works permit or municipal drinking water licence or a written agreement if the system is receiving all its water from another system under an agreement.

The two reports have been combined and presented to council as the Annual Compliance and Summary Report.

**SECTION 11 ANNUAL REPORT****SYSTEM INFORMATION**

Drinking-Water System Name	CHAPLEAU DRINKING WATER SYSTEM
Drinking-Water System Number	220003494
Drinking-Water System Owner	The Corporation of the Township of Chapleau
Drinking-Water System Category	Large Municipal, Residential System
Population:	1,964
Reporting Period	January 1 to December 31, 2021

**REPORT AVAILABILITY**

Hard Copy Available at:	Township of Chapleau Municipal Office; 20 Pine Street, P.O. Box 129; Chapleau, ON P0M 1K0
Electronic Copy Available:	<a href="http://www.chapleau.ca">http://www.chapleau.ca</a>
Public Notification via:	Public access/notice

**DESCRIPTION OF THE DRINKING WATER SYSTEM**

The Chapleau Drinking Water System is owned by the Corporation of the Township of Chapleau. The treatment system is operated by the Ontario Clean Water Agency and the distribution system is operated by the Township of Chapleau Public Works Department. This subject system is not interconnected to any other drinking-water systems owned by different owners.

The Chapleau Water Treatment Plant, built in 1975, draws raw water for the municipal system from the Kebsquasheshing River (Chapleau River). Water passes through a concrete screening chamber and then through one of three 500 Imp. Gal. /min low lift pumps in the raw water well. There are no critical upstream or downstream processes relied upon to ensure the provision of safe drinking water.

The raw water is directed to a pre-contact tank where aluminum sulphate (alum) is added as a coagulant, polyelectrolyte (polymer) is added as a coagulant aid and sodium carbonate (soda ash) is added for pH and alkalinity adjustment. The pre-contact tank is also equipped with a chlorine injection line for pre-chlorination if required. After a short residence time, water flows by gravity to one of two clarifier tanks, which are equipped with 30-degree tube settlers and sludge scrapers. Clarified water passes through the upflow settlers and directed into two dual media filters, each comprised of silicate sand and anthracite coal. The filters backwash automatically based on filter runtime or head pressure.

The filtered water is then chlorinated and directed to a series of three reservoirs and three clearwells to provide adequate contact time. The combined storage volume is 1 818 400 litres.

Water levels in the clearwells are used to control the plant's production. Two 20 hp high lift pumps and four 60 hp high lift pumps are utilized in clearwell 1 and 2 to direct treated water to the distribution system. Before entering the distribution system the treated water is dosed with soda ash for pH adjustment and ammonium sulphate to provide secondary disinfection through chloramination.

A diesel generator is connected to allow the treatment plant to remain in operation should a power failure occur. The water treatment process is controlled by a dedicated PLC and monitored through the SCADA computer system.

The distribution system is constructed primarily of ductile iron, and provides fire protection to the Township of Chapleau as well as drinking water. There are no water storage facilities in the distribution system, as storage is incorporated within the treatment plant. Based on the number of service connections, the system is classified as a Large Municipal Drinking Water System.

### **WATER TREATMENT CHEMICALS USED**

The following chemicals were used in the Chapleau Drinking Water System treatment process:

- Aluminum Sulphate (Alum) – Coagulation/Flocculation
- Ammonium Sulfate – Secondary Disinfection
- Chlorine Gas – Primary Disinfection
- Polyelectrolyte (Polymer) - Coagulant Aid
- Sodium Carbonate (Soda Ash) – pH and Alkalinity Adjustment

All treatment chemicals are NSF/ANSI approved.

### **SIGNIFICANT EXPENSES INCURRED TO THE DRINKING WATER SYSTEM**

The following work was completed in 2021:

- Chemical costs
- DWQMS third party audit
- Chemical drum pump for filter wash
- Pallet jack
- Chlorine analyzer membranes
- Header replacement (Township project)
- Backflow preventer calibrations
- Genset servicing
- Sommer's genset repair

## REPORTED ADVERSE TEST RESULTS AND OTHER PROBLEMS

Sample Date    Details (Parameter, Limit, Result, Corrective Action, Date, etc.)

MAY 19	AWQI 154086 Turbidity analyzer failed after calibration and the plant continued to run, incorrectly reading from 13:52 to 19:52. There was no indication of a process upset. Please refer to the original Notices of Adverse Test Results and Issue Resolution (Schedule 16) for full details
OCTOBER 26	AWQI 156214 PLC crash caused a loss of pressure in the distribution system for approximately 10 minutes (10:17 to 10:27). MOH issued a DWA which was then lifted on October 29
DECEMBER 13	AWQI 157401 Distribution sample result was NDOGN, MOH issued a system wide BWA, which was lifted December 17

*Please refer to the original Notices of Adverse Test Results and Issue Resolution (Schedule 16) for full details*

## SCHEDULE 7 – OPERATIONAL TESTING

### Continuous Flow Analyzers in Treatment Process

Parameter	Number of Samples	Range of Results (min to max)	Unit of Measure
Turbidity (Filter 1)	8760	0 to 2.0	NTU
Turbidity (Filter 2)	8760	0 to 2.0	NTU
Free Chlorine	8760	0.34 to 2.88	mg/L

Note: For continuous monitors use 8760 as the number samples for one year.

Effective backwash procedures are in place to ensure that the effluent turbidity requirements are met all times.

### Combined Chlorine Residual in the Distribution System

Number of Samples	Combined Chlorine (min to max)	Unit of Measure	Standard
365	0.30 to 2.38	mg/L	≥ 0.25 and <3.0

Note: Combined chlorine residuals are collected and tested daily.

## SCHEDULE 10 – MICROBIOLOGICAL TESTING

Sample Type	Number of Samples	<i>E.coli</i> Results (min to max)	Total Coliform Results (min to max)	Number of HPC Samples	Range of HPC Results (min to max)
Raw	52	0 – 30	6 – 930	N/A	N/A
Treated	52	0 – 0	0 – 0	52	<10 – 30

Sample Type	Number of Samples	<i>E.coli</i> Results (min to max)	Total Coliform Results (min to max)	Number of HPC Samples	Range of HPC Results (min to max)
Distribution	165	0 – NDOGN	0 – NDOGN	104	<10 – 90
MAC	-	0	0	-	-

Maximum Acceptable Concentration (MAC) applies only to treated or distribution samples  
 NDOGN – No data overgrown with non-target organisms

### SCHEDULE 13 - NITRATE AND NITRITE AT THE WATER TREATMENT PLANT

Date of Sample	Nitrate Result (mg/L)	Nitrite Result (mg/L)	Exceedance
January 4, 2021	<0.05	<0.05	No
April 7, 2021	0.16	<0.05	No
July 13, 2021	<0.05	<0.05	No
October 4, 2021	<0.05	<0.05	No
MAC	10	1	-

### SCHEDULE 13 – TOTAL TRIHALOMETHANES IN THE DISTRIBUTION SYSTEM

Date of Sample	THM Result (ug/L)	Four Quarter Running Average	Exceedance
January 4, 2021	57.2	69.3	No
April 7, 2021	45.6	69.9	No
July 13, 2021	97.6	64.6	No
October 4, 2021	52.0	63.1	No

MAC for Trihalomethanes = 100 ug/L (Four Quarter Running Average)

### SCHEDULE 13 – HALOACETIC ACIDS (HAA) IN THE DISTRIBUTION SYSTEM

Date of Sample	HAA Result (ug/L)	Four Quarter Running Average	Exceedance
January 4, 2021	<8	45.0	No
April 7, 2021	52	52.8	No
July 13, 2021	97	51.5	No
October 4, 2021	62	54.8	No

MAC for Haloacetic acids = 80 ug/L (Four Quarter Running Average)

### SCHEDULE 13 – SODIUM AT THE WATER TREATMENT PLANT

Date of Sample	Number of Samples	Result Value (mg/L)	MAC	Exceedance
October 9, 2018	1	26.7	20	Yes (AWQI 143653)

Date of Sample	Number of Samples	Result Value (mg/L)	MAC	Exceedance
October 22, 2018	1	23.5	20	N/A Re-sample

Note: Sample required every 60 months.

Sodium exceedances are reported if there has not been an adverse reported in the previous 57 months.

### SCHEDULE 13 – FLUORIDE AT THE WATER TREATMENT PLANT

Date of Sample	Number of Samples	Result Value (mg/L)	MAC	Exceedance
October 9, 2018	1	<0.025	1.5	No

Note: Sample required every 60 months.

### SCHEDULE 15.1 – LEAD IN THE DISTRIBUTION

The Chapleau Drinking Water System qualified for the ‘Exemption from Plumbing Sampling’ as described in section 15.1-5 (9-10) of Ontario Regulation 170/03.

As such, the system is required to test for total alkalinity and pH in two distribution samples collected during the periods of December 15 to April 15 and June 15 to October 15. This testing is required in every 12-month period with lead testing in every third 12-month period.

Sampling Dates	Number of Samples	Range of Results (min to max)		
		Lead (ug/L)	pH	Alkalinity (mg/L)
<b>Winter Period</b>				
April 8, 2020	2	0.1 – 0.1	-	-
April 7, 2021	2	-	7.41 – 7.58	52 – 53
<b>Summer Period</b>				
October 5, 2020	2	<0.1 – 0.1	-	-
September 27, 2021	2	-	7.04 – 7.09	59 – 64

MAC for lead is 10 ug/L

### SCHEDULE 23 – INORGANIC PARAMETERS AT THE WATER TREATMENT PLANT

Sample Date: October 5, 2021

Parameter	Result (ug/L)	MAC	MAC Exceedance	1/2 MAC Exceedance
Antimony	<0.5	6	No	No
Arsenic	<1	25	No	No
Barium	15	1000	No	No
Boron	5	5000	No	No
Cadmium	<0.1	5	No	No



Parameter	Result (ug/L)	MAC	MAC Exceedance	1/2 MAC Exceedance
Chromium	<1	50	No	No
Mercury	<0.1	1	No	No
Selenium	0.4	10	No	No
Uranium	<1	20	No	No

MAC – Maximum Acceptable Concentration

No inorganic parameter(s) exceeded half the standard found in Schedule 2 of the Ontario Drinking Water Standards (ODWS) during the reporting period

## SCHEDULE 24 – ORGANIC PARAMETERS AT THE WATER TREATMENT PLANT

Sample Date: October 5, 2021

Parameter	Result (ug/L)	MAC	MAC Exceedance	1/2 MAC Exceedance
1,1-Dichloroethylene	<0.5	14	No	No
1,2-Dichlorobenzene	<0.5	200	No	No
1,2-Dichloroethane	<0.5	5	No	No
1,4-Dichlorobenzene	<0.5	5	No	No
2,3,4,6-Tetrachlorophenol	<0.3	100	No	No
2,4,6-Trichlorophenol	<0.3	5	No	No
2,4-Dichlorophenol	<0.393	900	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	<0.3	100	No	No
Alachlor	<0.246	5	No	No
Atrazine + N-dealkylated metabolites	<0.5	5	No	No
Azinphos-methyl	<0.184	20	No	No
Benzene	<0.2	1	No	No
Benzo(a)pyrene	<0.01	0.01	No	No*
Bromoxynil	<0.105	5	No	No
Carbaryl	<3	90	No	No
Carbofuran	<4	90	No	No
Carbon Tetrachloride	<0.2	2	No	No
Chlorobenzene (Monochlorobenzene)	<0.5	80	No	No
Chlorpyrifos	<0.184	90	No	No
Diazinon	<0.184	20	No	No
Dicamba	<0.0917	120	No	No
Dichloromethane (Methylene Chloride)	<5	50	No	No
Diclofop-methyl	<0.131	9	No	No

Parameter	Result (ug/L)	MAC	MAC Exceedance	1/2 MAC Exceedance
Dimethoate	<0.184	20	No	No
Diquat	<0.2	70	No	No
Diuron	<10	150	No	No
Glyphosate	<20	280	No	No
Malathion	<0.184	190	No	No
MCPA (2-methyl-4-chlorophenoxyacetic acid)	<6.55	100	No	No
Metolachlor	<0.123	50	No	No
Metribuzin	<0.123	80	No	No
Paraquat	<0.3	10	No	No
Pentachlorophenol	<0.4	60	No	No
Phorate	<0.123	2	No	No
Picloram	<0.0917	190	No	No
Prometryne	<0.0614	1	No	No
Simazine	<0.184	10	No	No
Terbufos	<0.123	1	No	No
Tetrachloroethylene	<0.5	10	No	No
Total PCB	<0.06	3	No	No
Triallate	<0.123	230	No	No
Trichloroethylene	<0.5	5	No	No
Trifluralin	<0.123	45	No	No
Vinyl Chloride	<0.1	1	No	No

Note\*: Benzo(a)pyrene – Schedule 13-5 of O. Reg. 170/03 requires increased frequency of sampling if an analytical result obtained for any of the parameters listed in Schedule 24 exceeds one half of the MAC. The Ministry has set the reporting detection limit (RDL) for Benzo[a]pyrene at 50 per cent or more of the MAC, due to the limitations of the current analytical methods to achieve lower detection limits. The RDL for benzo[a]pyrene is 0.01 ug/L. For this parameter, a licenced laboratory must be able to achieve a method detection limit (MDL) at least equal to the RDL. A positive result above their MDL would trigger increased frequency of sampling, but a result equal to their MDL would not

No organic parameter(s) listed in 24 of Ontario Regulation 170/03 exceeded half the standard found in Schedule 2 of the Ontario Drinking Water Standard (O. Reg. 169/03) during the reporting period.

#### ADDITIONAL TESTING AND SAMPLING

No additional sampling and testing was required during the reporting year.

## SCHEDULE 22 – SUMMARY REPORTS FOR MUNICIPALITIES

This report is a summary of water quality information for the Chapleau Water Treatment System. It is published in accordance with Schedule 22 of Ontario’s Drinking Water Systems Regulation 170/03 for the reporting period of January 1 to December 31, 2021 and must be submitted to members of council.

The report must list the requirements of the Safe Drinking Water Act (2002) and the drinking water regulations which can be viewed at the following website:

<http://www.e-laws.gov.on.ca>.

### PERMITS AND LICENCES

Municipal Drinking Water Licence (MDWL)	222-101 (issued March 3, 2021)
Drinking Water Works Permit (DWWP)	222-201 (issued March 3, 2021)
Permit to Take Water (PTTW)	3048-B74SEA Issued December 5, 2018

### REQUIREMENTS THE SYSTEM FAILED TO MEET

The following table lists the requirements of the Safe Drinking Water Act (2002), the drinking water regulations, the system’s approval, drinking water works permit, municipal drinking water works licence, and any other orders applicable to the system that were not met at any time during the reporting period. This table is based on documentation available to the Ontario Clean Water Agency. The duration of the failure and details of the actions that were taken to correct the failure must be described.

Legislation	Requirement(s) the System Failed to Meet, Corrective Actions and Status
MDWL	May 31 – treated flows were not recorded from 02:15 to 15:05 when the flow meter failed. Instrumentation technician came on-site to install a temporary flow meter
	June 2 – treated flows were not recorded from 04:15 to 07:28 when the temporary flow meter failed. The unit was discovered powered off at 05:20 and again at 19:28. The cord was discovered to be faulty and was replaced.
	October 29 – treated flows were not recorded from 08:00 to 10:20 during header upgrades. Portable flow meter was moved from the bypass line to the new line which had to be abandoned due to a significant leak. The leak was repaired and flow was recorded when normal operations resumed
O. Reg. 170/03	October 26 – no on-line monitoring from 10:17 to 10:48 for flows, chlorine residuals, filter turbidity, etc. PLC crash caused the system to need to be restarted. The initial focus was on restoring pressure to the system.
O. Reg. 170/03 (1-2(2))	From the MECP report following the inspection on September 27, 2021: Records did not indicate that the treatment equipment was operated in a

Legislation	Requirement(s) the System Failed to Meet, Corrective Actions and Status
	<p>manner that achieved the design capabilities required under Ontario Regulation 170/03 or a Drinking Water Works Permit and/or Municipal Drinking Water Licence issued under Part V of the SDWA at all times that water was being supplied to consumers.</p> <p>On October 26, 2021 a loss of pressure event occurred due to a programmable logic controller failure. The operators were fortunately on-site at the time and were quickly able to restore pressure to the system, however the system was depressurized for approximately 10 minutes</p>

### SUMMARY OF QUANTITIES AND FLOW RATES

For the purpose of enabling the owner of the system to assess the rated capacity of their system to meet existing and future planned water uses, the following information is also required in the report. Under schedule 22-2(3) of Ontario Regulation 170/03, the Summary Report must include the following:

1. A summary of the quantities and flow rates of water supplied, including the monthly average and the maximum daily flows
2. A comparison of both the average and maximum flow rate summary to the rated capacity approved in the systems approval, drinking water works permit or municipal drinking water licence

The following tables and graphs indicate the quantities and flow rates of water taken and produced during the reporting period, including monthly average flows, maximum daily flows and the total monthly volumes. A comparison of the water data is made to the rated capacity and flow rates specified in the system's Municipal Drinking Water Licence.

### MONTHLY SUMMARY OF WATER TAKINGS FROM THE KEBSQUASHESHING RIVER

	Maximum (L/min)	Maximum (m <sup>3</sup> /d)	Average (m <sup>3</sup> /d)	Total Usage (m <sup>3</sup> )
January	2,121	1,792	1,306	40,476
February	2,219	1,736	1,323	37,051
March	2,198	1,527	1,241	38,460
April	2,162	1,209	1,121	33,624
May	2,303	1,205	1,082	33,549
June	2,355	1,545	1,178	35,346
July	1,993	1,481	1,200	37,213
August	2,098	1,638	1,352	41,906
September	2,258	1,327	1,201	36,041
October	2,120	1,558	1,232	38,179

	Maximum (L/min)	Maximum (m <sup>3</sup> /d)	Average (m <sup>3</sup> /d)	Total Usage (m <sup>3</sup> )
November	1,990	2,101	1,258	37,745
December	2,256	1,307	1,168	36,200

## MONTHLY SUMMARY OF TREATED WATER SUPPLIED TO THE DISTRIBUTION SYSTEM

	Total Usage (m <sup>3</sup> )	Average (m <sup>3</sup> /d)	Maximum (m <sup>3</sup> /d)	% Rated Capacity
January	20,340	656	705	10.4
February	21,918	783	994	12.4
March	24,594	793	1,006	12.5
April	20,342	678	734	10.7
May	19,725	636	719	10.0
June	23,273	776	1,033	12.2
July	23,708	765	937	12.1
August	29,472	951	1,177	15.0
September	23,846	795	919	12.6
October	26,079	841	1,199	13.3
November	30,757	1,025	1,181	16.2
December	31,423	1,014	1,075	16.0

## FLOW MONITORING

Municipal Drinking Water Licence (MDWL) requires the owner to install a sufficient number of flow measuring devices to permit the continuous measurement and recording of:

- the flow rate and daily volume of water conveyed from the treatment system to the distribution system, and
- the flow rate and daily volume of water conveyed into the treatment system.

The Chapleau drinking water system has two flow meters as listed in the MDWL; one installed to monitor raw water entering the treatment plant and one installed to monitor treated water entering the distribution system. Flow metering devices were calibrated in accordance to manufacturers' specifications on an annual basis and are operating as required.

## SUMMARY OF FLOW COMPARISON

### COMPARISON OF RAW FLOWS TO SYSTEM'S PERMIT TO TAKE WATER

<b>Permit to Take Water Limits (PTTW) - maximum</b>	<b>4,400 m<sup>3</sup>/day</b>	<b>4,419 L/min</b>
Average Daily Flow for 2021	1,222 m <sup>3</sup> /day	875 L/min
Maximum Daily Flow for 2021	2,101 m <sup>3</sup> /day	2,355 L/min
Total Raw Water Used in 2021	445,789 m <sup>3</sup>	-

**COMPARISON OF TREATED FLOWS TO SYSTEM'S MUNICIPAL DRINKING WATER LICENCE**

<b>Rated Capacity of the Plant (MDWL)</b>	<b>6,333 m<sup>3</sup>/day</b>	
Average Daily Flow for 2021	809 m <sup>3</sup> /day	12.8 % of the rated capacity
Maximum Daily Flow for 2021	1,199 m <sup>3</sup> /day	18.9 % of the rated capacity
Total Treated Water Produced in 2021	295,476 m <sup>3</sup>	

Based on the information above, the plant is able to meet the demands of the consumers.