



Operations Division Occupational Health and Safety

0 - 3

FEB 13 12

OHS Case ID: 02779FCPW009  
Field Visit no: 02779FCPW010 Visit Date: 2012-JAN-31 Field Visit Type: INITIAL

Workplace Identification: CORP OF THE TWP OF CHAPLEAU, THE  
20 PINE STREET, CHAPLEAU TWP, ON, CANADA P0M 1K0 Notice ID:

Telephone: (705) 864-1330 JHSC Status: Inactive Work Force #: 4 Completed %:

Persons Contacted: KEVIN MORRIS - H&S MANAGER  
Visit Purpose: INSPECTION  
Visit Location: RECREATION CENTER OFFICE  
Visit Summary: ACCOMPANIED BY L. WAKELY - MOL HYGIENIST. SEE DETAILED NARRATIVE BELOW

Detailed Narrative:

Occupational Hygiene Comments – January 31, 2011  
L. Wakely, ROH.

The museum is a small log building built in approximately 1967. The facility is closed from September until June. A concern had been noted about mould in the facility and a consulting firm has been contracted to conduct an assessment of the facility prior to opening for the 2012 season. The proposal to provide Mould Assessment services for the Chapleau Museum (#04001331) dated December 19, 2012, was reviewed. The employer reported that the facility will not be reopened until the mould assessment is completed and until that time access to the building will be limited. Any workers required to enter the facility will be informed of the possible presence of mould and given appropriate personal protective equipment.

No concerns were raised by workers in the facility during the 2011 season. A water leak was reported to have happened in a previous winter but the flood was cleaned up, the area dried, and the carpets were removed for cleaning.

It is important to note that control of water infiltration and ensuring that wetted areas are quickly dried is key in controlling potential sources of mould contamination in indoor air quality. The following documents discuss mould in indoor environments and good practices to follow if water leaks occur.

MOL Hazard Alert regarding mould <http://www.labour.gov.on.ca/english/hs/alerts/a20.html>

Occupational Health and Safety Council of Ontario – Mould; Workplace guidelines for recognition, assessment and control. <http://www.iapa.ca/pdf/moulds.pdf>

Occupational Health Clinics for Ontario Workers. – mould fact sheet

Recipient	Inspector Data	Worker Representative
Name <u>Kevin Morris</u>	<b>MICHEL LACROIX</b> OCCUPATIONAL HEALTH & SAFETY INSPECTOR PROVINCIAL OFFENCES OFFICER 70 FOSTER DR, SUITE 480 SAULT STE MARIE, ON P6A 6V4 Tel: 705-945-5845 Fax: 705-949-9796	Name _____
Title <u>L.C.S.O.</u>		Title _____
Signature <u>[Handwritten Signature]</u>	Signature <u>[Handwritten Signature]</u>	Signature _____

You are required under the Occupational Health and Safety Act to post a copy of this report in a conspicuous place at the workplace and provide a copy to the health and safety representative or the joint health and safety committee if any. Failure to comply with an order, decision or requirement of an inspector is an offence under Section 66 of the Occupational Health and Safety Act. You have the right to appeal any order or decision within 30 days of the date of the order issued and to request suspension of the order or decision by filing your appeal and request in writing on the appropriate forms with the Ontario Labour Relations Board, 505 University Ave., 2nd Floor, Toronto, Ontario M5G 2P1. You may also contact the Board by phone at (416) 326-3335 or 1-877-339-3335 (toll free), mail or by website at <http://www.gov.on.ca/lab/olrb/home.htm> for more information.