Press TAB to move to in: Energy Consumption and Greenhouse Gas Emissions Reporting - for 2013:																			
Confirm consecutive	 																		
12-mth period (mth-																			
yr to mth-yr)z	Jan/2013 - Dec/20132																		
Sector	Municipality:																		
Agency Sub-sector:	Municipal:																		
Organization Name:	Township of Chapleau																		
					Avg		Energy Type and Amount Pur		chased and Consumed in Natural Units:			Total (calculated in webform):							
					Total Floor	•	hrsz	Annual Flow	Electrici		Fuel Oil 1 & 2	2z	Propane	z	GHG z	Energy z	Energy z	Building	/
Operation Namez	Operation Typez	Addressz	Cityz	Postal Cod	e Areaz	Unitz	/wkz	(Mega Litres):	Quantity:	Unit	Quantity Uni	it Qua	iantity:	Unit	Emissionsz	Intensityz	Intensityz	Operation	oz Comments
Centennial Museum	Cultural facilities	Monk Street	Chapleau	P0M 1K0	1,538.00	Square feet	48	0.00000	1.00000	kWh					0.07601	0.00065	0.00000)	Facility is closed.
Civic Centre	lem:lem:lem:lem:lem:lem:lem:lem:lem:lem:	Pine Street	Chapleau	P0M 1K0	4,483.00	Square feet	40	0.00000	86,230.31000) kWh					6,554.53832	19.23496	0.00000)	
Dufferin Lift Station	Other	Dufferin Street	Chapleau	POM 1K0	392.88	Square feet	168	0.00000	44,768.82000) kWh					3,402.96755	113.95037	0.00000)	
Fire Hall	Fire stations and associated offices and facilities	Pine Street	Chapleau	POM 1K0	6,028.00	Square feet	168	0.00000	115,964.90000) kWh					8,814.72398	19.23771	0.00000)	WE OPERATE A VOLUNTEER FIRE DEPARTMENT
Lisgar Lift Station	Facilities related to the pumping of sewage	Lisgar Street	Chapleau	P0M 1K0	0.00		168	36.41100	12,651.02000) kWh					961.62933	0.00000	347.45050)	
Moore Arena	Indoor ice rinks	Maple Street	Chapleau	P0M 1K0	49,779.00	Square feet	108	0.00000	1,070,803.00000) kWh	3393 Litre				81,393.87764	21.51114	0.00000)	
Public Library	Public libraries	Pine Street	Chapleau	P0M 1K0	4,946.00	Square feet	32	0.00000	95,150.68000) kWh					7,232.59349	19.23791	0.00000)	
Public Works Garage	Storage facilities where equipment or vehicles are maintained, repaired or stored	Martel Road	Chapleau	POM 1K0	6,520.00	Square feet	40	0.00000	42,182.47000) kWh			19,543 Lit	tre)	
Riverside Lift Station	Other	Riverside Drive:	Chapleau	P0M 1K0	449.93	Square feet	168	0.00000	115,112.10000) kWh					8,749.90095)	
Sewage Treatment Pl	Facilities related to the treatment of sewage	Riverside Drive:	Chapleau	P0M 1K0	0.00		168	589.74800	161,511.40000) kWh					12,276.80454	0.00000	273.8651	1	
Water Plant	Facilities related to the treatment of water	Water Plant Road	Chapleau	P0M 1K0	0.00		168	343.79100	628,376.50000) kWh					47,764.1545	0.00000	1,827.7863	5	